

Nashoba Analytical, LLC

31A Willow Road, Ayer MA 01432

Client:

Nashoba Assoc. Boards of Health
30 Central Avenue
Ayer, MA 01432

Tel: 978-391-4428 Fax: 978-391-4643
Website: <http://www.NashobaAnalytical.com>

LabNumber: **122764**
Use this number with all correspondence

ReportDate: 8/2/2011

Certificate of Analysis

Parameter	Method	Result	MRL	Date of Analysis	Analyst
NABH# NA2523 Littleton, Town Beach <i>Sampled: 8/1/2011 12:38:00 PM by A Luschen</i>					
E.coli, /100ML	EPA 1603	32 ✓	2	8/1/2011 4:00:00 PM	M-MA1118

OK
[Signature]

RECEIVED
BY:

Recreational Water Limits:
E.coli Limit= 235/100ml
Enterococcus Limit=61/100ml
MRL = Minimum Reporting Level
Massachusetts Certified
Laboratory #MA1118

David L. Knowlton
David L. Knowlton
Laboratory Director