

## Maren Toohill

---

**From:** Josh DeTerra <jdeterra@lelwd.com>  
**Sent:** Thursday, March 9, 2023 2:48 PM  
**To:** Maren Toohill  
**Cc:** Pat Laverty  
**Subject:** 550 Newtown Road LELD Comments

**\*\*THIS EMAIL WAS SENT BY AN EXTERNAL SENDER\*\***

Good afternoon Maren,

Please see LELD comments for the project at 550 Newtown Rd below.

LELD intends to install a new three phase riser pole adjacent to existing pole with existing transformers on eastern side of property. New transformer to feed existing service to existing building and new service to new building.

- An easement for all new infrastructure must be granted to LELD before construction.
- LELD must receive detailed site drawings approved by the Planning Board (in .dwg and .pdf format) before starting the electric site utility design.
- Developer must provide LELD with a load letter indicating the total number of electric metered services within this development. The load letter must also include the total connected load for each metered service.
- 3 phase transformers need to show bollards around them on all site/utility plans.
- Developer must comply with the latest version of the LELD Construction Handbook.
- Once approved by the Planning Board, LELD will require a meeting with the developer to go over loading and other electrical requirements.
- New transformer to be in location accessible to LELD trucks and agreed upon by developer and LELD.

Thank you,

**Joshua DeTerra**  
Senior Electrical Engineer  
Littleton Electric Light and Water Departments  
(978) 540-2263  
[jdeterra@lelwd.com](mailto:jdeterra@lelwd.com)