



**Nashoba Associated Boards of Health
Environmental Health Service
30 Central Avenue, Ayer, Ma. 01432**

M E M O

DATE: May 2, 2011
TO: Keith A. Bergman, Town Administrator
FROM: Jim Garreffa 
RE: 15 GREAT RD., LITTLETON

Based on the presentation on 4/15/11 I have the following comments.

Sewage disposal

Given the scope of the project a groundwater discharge permit (from Department of Environmental Protection DEP) and a sewage disposal construction works permit (from the Littleton Board of Health) will be required.

Blasting

If blasting is required for site construction, the materials used for blasting should not contain perchlorate; blasting with materials containing this compound has been linked to the contamination of groundwater with perchlorate.

Retention/Detention basins

Any basins should be designed to minimize their potential for becoming mosquito breeding areas.