



GRANITE STATE ANALYTICAL SERVICES, LLC.

22 Manchester Road, Unit 2, Derry, NH 03038
Phone (800) 699-9920 | (603) 432-3044 website www.granitestateanalytical.com

Laboratory Report

Skillings & Sons, Inc.
9 Columbia Dr
Amherst, NH 03031

Date Printed: 03/08/2024
Work Order #: 2402-04529
Client Job #: 92080
Date Received: 02/29/2024
Sample collected in: Massachusetts

Attached please find results for the analysis of the samples received on the date referenced above.

Unless otherwise noted in the attached report, the analyses performed met the requirements of the analyzing laboratory's Quality Assurance Plan, Standard Operating Procedures and State Accreditation. This certificate shall not be reproduced, except in full, without the written approval of the analyzing laboratory. The results presented in this report relate to the samples listed on the following pages in the condition in which they were received. Accreditation for each analyte is identified by the * symbol following the analyte name. Location of our analyzing laboratory is identified by the code in the Analyst Column.

A & L Laboratory:
Identified by ME in Analyst Column
155 Center Street, Auburn, Maine 04210
www.allaboratory.com

Granite State Analytical Services LLC:
Identified by NH in Analyst Column
22 Manchester Road, Derry, NH 03038
www.granitestateanalytical.com

Nashoba Analytical:
Identified by MA in the Analyst Column
31A Willow Road, Ayer, MA 01432
www.nashobaanalytical.com

ANALYSIS RELATED NOTES:

- RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.
- DF: "Dilution factor" means the ratio of the volume of the sample to the volume of the final (dilute) solution.
- MDL: "Minimum Detection Limit" means the minimum result which can be reliably discriminated from a blank with a predetermined confidence level.
- A & L Laboratory / Granite State Analytical Services LLC / Nashoba Analytical. accreditation lists can be found on our websites listed above.
- Subcontracted samples will be identified by the Accreditation number of the subcontract laboratory in the analyst field for each analyte and the appropriate laboratory will be listed here. **None**
- Data Qualifiers (DQ) Flags provide additional information in regards to the receipt, analysis or quality control of a sample. These are indicated under the DQ Flags Column on your report and listed here if necessary: **Data Qualifier (DQ) Flags: None**


SAMPLE STATE SPECIFIC NOTES:

Additional Narrative or Comments: **None**

We appreciate the opportunity to provide you with laboratory services. If you have any questions regarding the enclosed report, please contact the laboratory and we will be happy to assist you.

Donald A. D'Anjou, Ph. D.
Laboratory Director

A & L Laboratory: Accreditations: Maine ME00021, New Hampshire 2501, Maine Radon Registration ID # SPC20
Granite State Analytical Services, LLC: Accreditations: New Hampshire 1015; Maine NH00003;
Massachusetts M-NH003; Rhode Island 101513; Vermont VT-101507
Nashoba Analytical: Accreditations: Massachusetts M-MA1118



GRANITE STATE ANALYTICAL SERVICES, LLC.

22 Manchester Road, Unit 2, Derry, NH 03038
Phone (800) 699-9920 | (603) 432-3044 website www.granitestateanalytical.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 03/08/2024
CLIENT NAME: Skillings & Sons, Inc.
CLIENT ADDRESS: 9 Columbia Dr
Amherst, NH 03031
SAMPLE ID #: 2402-04529-001
SAMPLED BY: Skillings & Sons, Inc.
SAMPLE ADDRESS: Town Of Littleton
75 Nagog Hill Road
Littleton MA 01460

Legend	
Passes	✓
Fails EPA Primary	✗
Fails EPA Secondary	⚠
Fails State Guideline	✗
Attention	⚠


DATE AND TIME COLLECTED: 02/28/2024 01:00PM
DATE AND TIME RECEIVED: 02/29/2024 10:06AM
ANALYSIS PACKAGE: Arsenic-MS
RECEIPT TEMPERATURE: ON ICE 2.3° CELSIUS

CLIENT JOB #: 92080

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date - Time Analyzed
Arsenic*	<0.001	mg/L	✓		0.001	0.010 mg/L	EPA 200.8	NM-NH	03/04/2024 05:25PM



Donald A. D'Anjou, Ph. D.
Laboratory Director



GRANITE STATE ANALYTICAL SERVICES, LLC.

22 Manchester Road, Unit 2, Derry, NH 03038
Phone (800) 699-9920 | (603) 432-3044 website www.granitestateanalytical.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 03/08/2024
CLIENT NAME: Skillings & Sons, Inc.
CLIENT ADDRESS: 9 Columbia Dr
Amherst, NH 03031
SAMPLE ID #: 2402-04529-002
SAMPLED BY: Skillings & Sons, Inc.
SAMPLE ADDRESS: Town Of Littleton
75 Nagog Hill Road
Littleton MA 01460

Legend	
Passes	✓
Fails EPA Primary	✗
Fails EPA Secondary	⚠
Fails State Guideline	✗
Attention	⚠

DATE AND TIME COLLECTED: 02/28/2024 01:00PM
DATE AND TIME RECEIVED: 02/29/2024 10:06AM
ANALYSIS PACKAGE: Skillings-Stain-MA
RECEIPT TEMPERATURE: ON ICE 2.3° CELSIUS

CLIENT JOB #: 92080

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date - Time Analyzed
Calcium*	13.2	mg/L			1	No Limit	EPA 200.7	JLR-NH	03/07/2024 01:29PM
Copper*	0.032	mg/L	✓		0.01	1.3 mg/L	EPA 200.7	JLR-NH	03/07/2024 01:29PM
Hardness (calc.)	46.6	mg CaCO ₃ /L			2	No Limit	EPA 200.7	JLR-NH	03/07/2024 01:29PM
Iron*	8.04	mg/L	⚠		0.2	0.3 mg/L	EPA 200.7	JLR-NH	03/07/2024 01:52PM
Magnesium	3.3	mg/L			1	No Limit	EPA 200.7	JLR-NH	03/07/2024 01:29PM
Manganese*	<0.01	mg/L	✓		0.01	0.05 mg/L	EPA 200.7	JLR-NH	03/07/2024 01:29PM

Donald A. D'Anjou, Ph. D.
Laboratory Director