

From: Nick Lawler
Sent: Monday, March 3, 2025 1:21 PM
To: Maren Toohill
Subject: FW: Site Plan Amendment - 100 Taylor Street

Please see comments from the Electric Department.

Thanks,

Nick Lawler, P.E.
General Manager
Littleton Electric Light and Water Departments
nlawler@lelwd.com
978.540.2251

From: Josh DeTerra <jdeterra@lelwd.com>
Sent: Monday, March 3, 2025 10:14 AM
To: Nick Lawler <NLawler@lelwd.com>; David Ketchen <dketchen@lelwd.com>
Subject: RE: Site Plan Amendment - 100 Taylor Street

Hi Nick,

My only comment for 100 Taylor Street is the following regarding load increase with the new addition:

Developer must provide LELD with a load letter indicating the total number of electric

- metered services within the new building(s), existing and new. The load letter must also include the total connected load for each metered service.

Thank you,

Joshua DeTerra
Supervisory Engineer; Electrical Dept.
Littleton Electric Light and Water Departments
(978) 540-2263
jdeterra@lelwd.com
LELWD hours are operation are Mon-Thurs 6:30am-4:30pm