

STAMSKI AND MCNARY, INC.

1000 Main Street
Acton, Massachusetts 01720
(978) 263-8585, FAX (978) 263-9883

PRINCIPALS

JOSEPH MARCH, P.E., P.L.S.
GEORGE DIMAKARAKOS, P.E.

ASSOCIATE

JONATHAN BOLLEN, P.L.S.

July 30, 2025

Conservation Commission
Town of Carlisle
66 Westford Street
Carlisle, MA 01741

Re: **Sewage Disposal Plan**
18 Pleasant Street
MassDEP#204-1024

Dear Members of the Commission,

On behalf of our client, Paul Dudley, a revised sewage disposal plan has been submitted for the referenced property in response to the comments received by members of the Conservation Commission at the hearing on July 22, 2025. We offer the following responses:

- A stockpile area has been proposed outside of the 100-foot Buffer zone where construction materials will be temporarily placed.
- All disturbed surfaces shall be restored with 4" of loam and conservation native seed mix within the 100' Buffer Zone. Refer to Note #14 on the revised plan.

Attached are onsite photos showing the staked sewage disposal system in relation to the proposed siltation barrier or limit of work.

We thank you for your attention to this matter. If you have any questions regarding this matter, please feel free to call.

Respectfully,

Stamski and McNary, Inc.

Montgomery Nsamba

Montgomery Nsamba



George Dimakarakos, P.E.





FENCE LINE BARRIER



